

CERTIFICATE

Certificate holder	Bänninger Kunststoff-Produkte GmbH Bänningerstr. 1 35447 Reiskirchen GERMANY
Production facility	Staßfurt
Product	Pressure pipes made of PP-RCT (Polypropylene random copolymer) for installation
Classification	EG 133 - Outer diameter 180 mm up to 355 mm
Testing basis	DIN EN ISO 15874-2:2013-06 Certification Scheme Plastic pipe system (pressure pipes and fittings (2017-05)

Mark of conformity

Registration No.	P1R0370
Valid until	2023-10-31
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

2019-01-30 *C. Seiser*
Dipl.-Phys. Carlo Seiser
Deputy Head of Certification Body



ANNEX

Page 1 of 1

Certificate	P1R0370 dated 2019-01-30
Technical Data	<p>Material: PP-RCT</p> <p>Type: see production facility related material list</p> <p>Colour:</p> <ul style="list-style-type: none">- green, similar to RAL 6024- customer related colour coding according to company standard specification <p>Weldable with:</p> <ul style="list-style-type: none">- Pipes and Fittings PP-R according to DIN EN ISO 15874 and Certification Scheme Annex J- Multilayer pipes PP-RCT / AL / PP-RCT according to Certification Scheme Annex I- Multilayer pipes PP-RCT / PP-RCT-GF / PP-RCT according to DIN EN ISO 21003-2 and Certification Scheme Annex H
Testing laboratory/ Inspection body	IMA Materialforschung und Anwendungstechnik GmbH Wilhelmine-Reichard-Ring 4 01109 Dresden GERMANY
Test report(s)	B597/15.5 dated 2016-05-03

