



## WaterMark Scope of Use

Installation of products under the WaterMark Schedule WM 74818 for ISO 15874 Parts 2 & 3 from Bänninger Kunststoff-Produkte GmbH, Germany shall be subject to the requirements of the appropriate regulatory authority, the National Plumbing Code of Australia Volume Three – PCA, AS/NZS 3500 (appropriate part), any associated reference standards and any Bänninger Kunststoff-Produkte GmbH product installation instructions.

The products listed under this schedule shall be installed by a licenced plumber and have the required qualifications for socket fusion, butt fusion and electro fusion welding.

All products should be inspected for leaks after installation.

This Scope of Use refers on the following products:

- PP-RCT fittings
- PP-RCT solid wall pipes POWERTEC and ECONTEC
- PP-RCT/glass fibre reinforced pipes WATERTEC and CLIMATEC
- 

Note – pipes and fittings not to be welded to PE pipes/fittings.

Welding connections to other PP manufacturers products are out of warranty.

For hot and cold water installations.

Joining methods are socket fusion, butt fusion, electro fusion, BSP Male and female threads and flange adaptors.

Suitable for indoor use, outdoor use only with UV-protected pipe and additional UV-protection for fittings ( above ground installations ).

See manual for installation rules

Max. Temp: 95°C

Note - Concerning max. pressure and application classes according ISO 15874 see detailed information for each type of pipe in the manual.

Reiskirchen, September 2020